

放 流 水 中 の 有 害 成 分

令和 7年度

月 日	アルキル水銀 mg/l	総水銀 mg/l	カドミウム mg/l	鉛 mg/l	有機リン mg/l	六価クロム mg/l	シアン mg/l	ひ素 mg/l	PCB mg/l	フェノール mg/l	銅 mg/l	亜鉛 mg/l	総クロム mg/l	ふっ素 mg/l	溶解性鉄 mg/l	溶解性マンガン mg/l	1.4ジオキシン類 mg/l	ダイオキシン類 pg-TEQ/l
4/16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.010	0.025	ND	ND	0.05	0.026	ND	—
6/11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.031	ND	ND	0.06	0.021	ND	—
8/6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	0.029	ND	ND	0.05	0.030	ND	0.00061
10/8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.029	ND	ND	0.05	0.031	ND	—
12/3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	0.029	ND	ND	0.06	0.035	ND	—
2/4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.009	0.034	ND	ND	0.05	0.031	ND	—
最高	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.010	0.034	ND	ND	0.06	0.035	ND	—
最低	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	0.025	ND	ND	0.05	0.021	ND	—
平均	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.007	0.030	ND	ND	0.05	0.029	ND	—
定量下限	0.0005	0.0005	0.0003	0.001	0.01	0.002	0.01	0.001	0.0005	0.005	0.001	0.001	0.001	0.1	0.03	0.001	0.005	
検出下限	0.0002	0.0002	0.0001	0.0003	0.003	0.0006	0.003	0.0003	0.0002	0.002	0.0003	0.0002	0.0003	0.009	0.005	0.0003	0.0005	
基準	検出されないこと	0.005	0.03	0.1	1	0.2	1	0.1	0.003	5	3	2	2	8	10	10	0.5	—

月 日	ノルマルヘキサン抽出物質 mg/l
4/16	ND
4/23	ND
5/7	ND
5/21	ND
6/11	ND
6/25	ND
7/2	ND
7/23	ND
8/6	ND
8/20	ND
9/10	ND
9/24	ND
10/8	ND
10/22	ND
11/5	ND
11/19	ND
12/3	ND
12/17	ND
1/7	ND
1/21	ND
2/4	ND
2/18	ND
3/4	ND
3/18	ND
最高	ND
最低	ND
平均	ND
定量下限	0.5
基準	動30 鉍5

月 日	トリクロロエチレン mg/l	テトラクロロエチレン mg/l	ジクロロメタン mg/l	四塩化炭素 mg/l	1.2ジクロロエタン mg/l	1.1ジクロロエチレン mg/l	シス1.2ジクロロエチレン mg/l	1.1.1トリクロロエタン mg/l	1.1.2トリクロロエタン mg/l	1.3ジクロロプロペン mg/l	ベンゼン mg/l	チウラム mg/l	シマジン mg/l	チオベンカルブ mg/l	セレン mg/l	ニッケル mg/l	ホウ素 mg/l	17β-エストラジオール μg/l	エストロン μg/l
4/16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.083	—	—
6/11	ND	ND	0.0005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.21	—	—
8/6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.19	0.0030	0.0593
10/8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.21	—	—
12/3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.22	—	—
2/4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.25	0.0022	0.0789
最高	ND	ND	0.0005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.25	—	—
最低	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.083	—	—
平均	ND	ND	0.0005	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.19	—	—
定量下限	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0006	0.0002	0.0002	0.001	0.001	0.001	0.001	0.001
検出下限	0.00002	0.00002	0.00001	0.00004	0.00002	0.00002	0.00001	0.00001	0.00002	0.00005	0.00002	0.0002	0.00006	0.00006	0.0003	0.0003	0.0003		
基準	0.1	0.1	0.2	0.02	0.04	1.0	0.4	3	0.06	0.02	0.1	0.06	0.03	0.2	0.1	—	10		