

放 流 水 中 の 有 害 成 分

令和 5年度

月 日	アルキル水銀 mg/l	総水銀 mg/l	カドミウム mg/l	鉛 mg/l	有機リン mg/l	六価クロム mg/l	シアン mg/l	ひ素 mg/l	PCB mg/l	フェノール mg/l	銅 mg/l	亜鉛 mg/l	総クロム mg/l	ふっ素 mg/l	溶解性鉄 mg/l	溶解性マンガン mg/l	1,4-ジチン mg/l	ダイキソ類 pg-TEQ/l
4/19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.018	0.029	ND	ND	0.04	0.019	ND	—
6/7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.016	0.031	ND	ND	0.07	0.030	ND	—
8/2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.014	0.029	ND	ND	0.06	0.020	ND	0.00028
10/11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.030	ND	ND	0.05	0.011	ND	—
12/6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.011	0.031	ND	ND	0.07	0.034	ND	—
2/7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.011	0.039	ND	ND	0.06	0.027	ND	—
最高	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.018	0.039	ND	ND	0.07	0.034	ND	—
最低	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.029	ND	ND	0.04	0.011	ND	—
平均	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.013	0.032	ND	ND	0.06	0.024	ND	—
定量下限	0.0005	0.0005	0.0003	0.001	0.01	0.002	0.01	0.001	0.0005	0.005	0.001	0.001	0.001	0.1	0.03	0.001	0.005	
検出下限	0.0002	0.0002	0.0001	0.0003	0.003	0.0006	0.003	0.0003	0.0002	0.002	0.0003	0.0002	0.0003	0.009	0.005	0.0003	0.0005	
基準	検出されないこと	0.005	0.03	0.1	1	0.5	1	0.1	0.003	5	3	2	2	8	10	10	0.5	—

月 日	ノルマルヘキサン抽出物質 mg/l
4/19	ND
4/26	ND
5/10	ND
5/24	ND
6/7	ND
6/21	ND
7/5	ND
7/19	ND
8/2	ND
8/17	ND
9/6	ND
9/20	ND
10/11	ND
10/25	ND
11/8	ND
11/22	ND
12/6	ND
12/20	ND
1/10	ND
1/24	ND
2/7	ND
2/21	ND
3/6	ND
3/19	ND
最高	ND
最低	ND
平均	ND
定量下限	0.5
基準	動30 鉍 5

月 日	トリクロロエチレン mg/l	テトラクロロエチレン mg/l	ジクロロメタン mg/l	四塩化炭素 mg/l	1,2ジクロロエタン mg/l	1,1ジクロロエチレン mg/l	シス1,2ジクロロエチレン mg/l	1,1,1トリクロロエタン mg/l	1,1,2トリクロロエタン mg/l	1,3ジクロロプロペン mg/l	ベンゼン mg/l	チウラム mg/l	シマジン mg/l	チオハブカルブ mg/l	セレン mg/l	ニッケル mg/l	ホウ素 mg/l	17β-エストラジオール μg/l	エストロン μg/l
4/19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.20	—	—
6/7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.20	—	—
8/2	ND	ND	0.0002	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.20	0.0076	0.124
10/11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.18	—	—
12/6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.23	—	—
2/7	ND	ND	0.0003	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.26	0.0462	0.0704
最高	ND	ND	0.0003	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.26	0.0462	0.124
最低	ND	ND	0.0002	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.18	0.0076	0.0704
平均	ND	ND	0.0003	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001	0.21	0.0269	0.0972
定量下限	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0006	0.0002	0.0002	0.001	0.001	0.001	0.001	0.001
検出下限	0.00002	0.00002	0.00001	0.00004	0.00002	0.00002	0.00001	0.00001	0.00002	0.00005	0.00002	0.0002	0.00006	0.00006	0.0003	0.0003	0.0003		
基準	0.1	0.1	0.2	0.02	0.04	1.0	0.4	3	0.06	0.02	0.1	0.06	0.03	0.2	0.1	—	10		